

1 Q. **Reference: Exhibit 9.**

2 With respect to NP's curtailable load program, please file all details on the program  
3 including the rate schedule, the compensation paid to customers, the justification  
4 that NP or Hydro can use to initiate an interruption, and the number of  
5 interruptions, by month (showing the number of interruptions, the capacity and  
6 energy interrupted, and the number of customers affected) since the 2008.

7

8

9 A. In the event of a system emergency such as a generation shortage or significant loss  
10 of transmission, Hydro follows a guideline which incorporates a series of actions in  
11 order to minimize the impact to customers. Depending on the severity of the  
12 situation, Hydro may call on Newfoundland Power to interrupt its curtailable load.  
13 A review of Hydro's control centre diaries could find indications of only two such  
14 requests from January 2008 to October 2013, both occurring in January 2013. The  
15 first occurred on January 25 at 16:09 hours and the second on January 28 at 14:00  
16 hours. Both requests were not able to be carried out do to the reasons outlined in  
17 Hydro's response to CA-NLH-176.

18

19 [ ]

20

21 In a review of Hydro's and Newfoundland Power's control centre diaries since  
22 October 2013 there were six curtailments noted, all occurring during the winter  
23 period of 2013/2014. The dates and times are summarized as follows:

Date	Start time	End Time
December 29, 2013	1600 hours	1945 hours
December 30, 2013	1600 hours	1930 hours
January 2, 2014	1600 hours	2100 hours
January 3, 2014	0800 hours	1400 hours
January 3, 2014	1600 hours	2100 hours
March 5, 2013	1630 hours	2100 hours

All of these requests occurred during Hydro's generation supply issues period this past winter.

Under Order P.U. 47(2014), the Board approved Hydro's proposal to revise its Utility rate, on an interim basis, to include a revised calculation of Newfoundland Power's billing demand to reflect a curtailable credit for the period December 1, 2014 to March 31, 2015. To provide for the maximum benefit for the system, this allows Hydro to request that Newfoundland Power curtail customer load only at times when the system requires it. The credit amount currently applied is 9,900 kW.