

1 Q. Re: IC-NLH-72. Is Hydro aware of the scale of curtailable load that NP has
2 subscribed? How many MW are under the program?

3

4

5 A. []

6

7 NP's forecast curtailable load for the 2014/2015 winter season is approximately 10

8 MW.