

1    Q.    Is Hydro aware of the use by NP of its curtailable load at peak times to reduce the  
2           NP contribution to system wide Island Interconnected System peaks?

3

4

5    A.    Hydro is aware of the use by NP of its curtailable load to reduce the NP contribution  
6           to system wide Island Interconnected System peaks only when Hydro makes a  
7           request of NP to use its curtailable load to assist in reducing system peaks.

8

9           It should be noted that NP's curtailable load program is administered and managed  
10          by NP and may be used by them to minimize their peak requirements from Hydro  
11          during NP's peak demand periods. Hydro is not generally made aware of NP's use of  
12          its curtailable load program for minimizing NP's peak demand periods.