

1    Q.    Does Hydro's response to IC-NLH-12 reflect NP peaks with the NP curtailable load  
2           curtailed, or operating as normal?

3

4

5    A.    The forecast NP native peaks, as provided by the customer and included in Hydro's  
6           response to IC-NLH-012, reflect NP peaks with the NP curtailable load curtailed.

7

8           The actual and weather adjusted NP native peaks included in Hydro's response to  
9           IC-NLH-012 will reflect NP peaks with NP curtailable load curtailed in some years  
10          but operating as normal in other years depending on if NP had requested its  
11          customers to curtail load at the time these peaks occurred.