

1     Q.     IC-NLH-099 Attachment 1 (Rev 1) and NP-NLH-131 (Rev 1) reveal no additions to the  
2           Corner Brook Frequency Converter assets in 2014 or 2015, but IC-NLH-087 (Rev 1)  
3           shows an addition of an online vibration monitoring system in (what appears to be)  
4           2014. Please reconcile the difference and provide a full description of the  
5           investment project and the proposed treatment of the project for COS purposes.

6  
7  
8     A.     The information provided in Hydro's response to IC-NLH-087 is accurate and should  
9           have been reflected in Hydro's responses to IC-NLH-099 (Revision 1, Dec 9-14) and  
10          NP-NLH-131 (Revision 1, Dec 19-14 ). The 2015 Test Year Cost of Service includes a  
11          forecast asset addition in 2014 of \$382,500 related to the Corner Brook Frequency  
12          Converter. Accordingly, it was allocated to Corner Brook Pulp and Paper as a  
13          specifically-assigned terminal station asset.

14  
15          The project to install an online vibration monitoring system was initially approved  
16          as part of the 2013 Capital Budget but was carried over to 2014. The project  
17          description is provided below:

18  
19                 It will provide real time vibration monitoring and diagnostics for the  
20                 converter, and have the capability to protect the unit through  
21                 programmable alarms and trip levels. This system will also provide  
22                 indication, through the communications system, to the Energy Control  
23                 Center (ECC). This project involves the installation of transducers on the 5  
24                 major bearing casings (See Figure 1) to measure vibration, and a cabinet to  
25                 house the vibration monitor (See Figure 2). Similar systems have been  
26                 installed at the Holyrood Thermal Generating station, and the Stephenville  
27                 and Hardwoods Gas Turbines. A temperature module and RTD's will also be  
28                 added to this system so that temperature monitoring and diagnostics are  
29                 available for the frequency converter.