

1 Q. Please reconcile total energy requirements for Island Interconnect System for 2015
2 Test Year in Regulated Activities, Schedule II [at 7,235.1 GW.h] and Regulated
3 Activities, Schedule V [7,239.0 GW.h].

4

5

6 A. Please note that total energy requirements for the Island Interconnect System for
7 the 2015 Test Year in Regulated Activities, Schedule II [at 7,235.1 GWh] is incorrect
8 as transmission losses of 225.7 GWh reported in Schedule II were incorrect. The
9 correct transmission losses for the 2015 test year are 229.5 GWh. Please see the
10 following table that reconciles total energy requirements for the Island
11 Interconnected System for 2015 Test Year. This error does not impact any other
12 schedules or costs reflected in Hydro's Amended Application.

13

	Regulated Activities	
	Schedule II	Corrected
	2015 Forecast	2015 Forecast
	<u>GWh</u>	<u>GWh</u>
Newfoundland Power	5,924.1	5,924.1
Hydro Rural Interconnected	463.9	463.9
Industrial Customers	<u>621.4</u>	<u>621.4</u>
Total Deliveries	7,009.4	7,009.4
Transmission Losses	<u>225.7</u>	<u>229.5</u>
Hydro Island Requirement	7,235.1	7,238.9