

1 Q. Further to PUB-NLH-390: For clarity please confirm that when calculating all Loss of
2 Load Probability calculations, as well as Peak Load Carrying Capabilities, wind
3 resources are ignored or provided a value of 0 MW. If not correct, please distinguish
4 which calculations consider wind to have any capacity value (and provide the value)
5 and which do not.

6
7
8 A. For all current and future Loss of Load Probability calculations, as well as Peak Load
9 Carrying Capabilities, the default assumption is/will be that wind resources are
10 ignored or provided a value of 0 MW. If for any reason (special studies or scenario
11 testing, etc.) wind resources are assumed to have a capacity value of more than 0
12 MW, this will be clearly stated and noted as a special case.