

Q. Re: Pre-filed Testimony of Larry Brockman, Section 4, Treatment of Curtailable Load.

Please provide, by month, for each of January, February, March, November and December for each of 2011, 2012 and 2013: NP's native peak, along with the NP generation, purchased power and curtailed load information for that interval, for: (1) NP's highest monthly native load exclusive of the effects of curtailments; (2) NP's highest monthly native load inclusive of the effects of curtailments; (3) NP's highest purchased power load.

A. Table 1 provides Newfoundland Power's highest monthly native peak exclusive of curtailments, highest monthly peak inclusive of curtailments and highest purchased power load for January, February, March, November and December for 2011 to 2013.

Table 1 Newfoundland Power's Native Peak Information¹ (kW)						
Year	Month	(1) Native Peak Exclusive of Curtailment	Curtailed Load²	(2) Native Peak Inclusive of Curtailment	Generation	(3) Highest Purchase Power Load
2011	January	1,138,273	-	1,138,273	89,154	1,049,119
	February ³	1,165,995	-	1,165,995	72,640	1,093,355
	March	1,096,818	-	1,096,818	74,007	1,022,811
	November	1,059,762	-	1,059,762	57,083	1,002,679
	December	1,229,343	-	1,229,343	43,018	1,186,325
2012	January	1,251,018	10,100	1,240,918	63,000	1,177,918
	February	1,197,371	-	1,197,371	43,792	1,153,579
	March	1,202,533	-	1,202,533	53,450	1,149,083
	November	NA	-	NA	NA	NA
	December	1,159,850	-	1,159,850	38,418	1,121,432
2013	January	1,267,556	-	1,267,556	83,471	1,184,085
	February	1,290,461	9,500	1,280,961	90,867	1,190,094
	March	1,171,940	-	1,171,940	74,592	1,097,348
	November	NA	-	NA	NA	NA
	December	1,344,142	8,400	1,335,742	59,412	1,276,330

¹ NA – Information that is currently unavailable and cannot be obtained in the time required to respond to this Request for Information. Peak load data for months outside the December to March winter season, are not routinely produced as they are not used for billing purposes.

² Includes load curtailed by customers and by load curtailed at Newfoundland Power facilities.

³ The Company did not request customers to curtail load during peak demand that occurred on February 2nd, 2011. The maximum demand requirement on that day, 1,166 MW, was below the previous winter season's peak of 1,206 MW at 7:45 am, February 3rd, 2010. It was determined at the end of March that the peak on February 2nd was the actual 2010/2011 winter season peak demand for Newfoundland Power.