

1 Q. **Re: NLH Evidence, Section 2, Schedule IV**

2 Please break down the category “Others” (Labrador Isolated), providing data for
3 each one of the Labrador isolated systems.

4

5

6 A. The following table below provides a break down for the “Others” category for
7 Hydro’s Evidence, Section 2, Schedule IV.

Newfoundland and Labrador Hydro
Actual and Forecast Electricity Requirements
Isolated Systems

	2007 Test Year		2007 Actual		2008 Actual		2009 Actual		2010 Actual		2011 Actual		2012 Actual		2013 Actual		2014 Forecast		2015 Forecast	
	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh	kW	MWh
Labrador Isolated																				
Others																				
Nain	1398	6,584	1,350	6,273	1,500	6,582	1,465	7,051	1,465	6,977	1,501	7,389	1,523	7,356	1,612	7,400	1,907	8,924	1,947	9,111
Makkovik	658	3,050	692	3,167	741	3,078	751	3,218	749	3,142	718	3,336	947	4,361	1,008	4,301	854	3,893	863	3,930
Cartwright	893	4,004	857	4,057	954	4,054	891	4,202	1,030	4,054	888	4,154	700	3,253	774	3,395	956	4,320	966	4,366
Hopedale	743	3,367	709	3,509	839	3,735	858	3,990	800	3,843	896	4,047	834	4,043	950	4,231	1,117	5,089	1,172	5,319
Rigolet	569	2,186	523	2,203	600	2,163	539	2,218	539	2,206	565	2,297	557	2,225	612	2,338	663	2,719	671	2,751
Black Tickle	431	1,157	434	1,213	494	1,326	490	1,340	422	1,279	415	1,307	250	1,108	266	1,092	239	1,065	235	1,047
Postville	329	1,486	344	1,599	383	1,563	370	1,687	380	1,639	432	1,807	391	1,586	445	1,605	486	2,138	490	2,157
Paradise River	28	80	34	84	36	90	30	95	41	99	40	116	37	118	56	147	41	113	42	115
Charlottetown	1432	4,973	1,419	4,641	1,476	5,110	1,434	4,918	1,691	5,108	1,468	5,144	1,468	5,431	1,304	5,571	1,614	5,409	1,614	5,409
Mary's Harbour	845	3,747	817	3,561	1,088	3,571	917	3,732	924	3,651	1,002	3,808	886	3,619	1,057	4,442	1,170	5,307	1,171	5,313
St. Lewis	457	1,614	488	1,604	510	1,616	466	1,597	460	1,557	448	1,594	345	1,386	369	1,409	366	1,456	364	1,447
Port Hope Simpson	733	2,934	735	2,883	778	2,962	663	3,024	754	3,225	719	3,307	747	3,283	702	3,108	777	3,411	793	3,476
William's Harbour	98	357	70	362	75	378	110	368	90	316	65	264	72	273	66	274	66	268	66	268
Norman Bay	49	164	67	186	62	193	66	204	76	200	51	183	57	165	60	192	55	203	55	203
Total Others	8,661	35,700	8,539	35,340	9,536	36,421	9,050	37,644	9,421	37,296	9,208	38,754	8,814	38,207	9,281	39,504	10,310	44,316	10,448	44,911

Notes:

1. The 2014 and 2015 forecasts are sourced to the Spring 2013 Rural Operating Load Forecast.
2. Peaks are non-coincident net annual maximums.
3. Net production excludes station services.
4. Operations ceased at Davis Inlet in early 2006 when the community moved to Natuashish.
5. Natuashish is operated by Hydro for the Mushuau Innu First Nation (MIFN) with full cost recovery