

1 Q. **Re: IN-NLH-034**

2 Please indicate if the installation of a new combustion turbine at Holyrood is still
3 planned for 2014-2015, despite the expected decommissioning of Holyrood as a
4 result of the Muskrat Falls project.

5

6

7 A. []

8

9 A new combustion turbine has been installed at Holyrood. As of March 2, 2015, the
10 new combustion turbine was officially made available to the grid at its full capacity
11 of 123.5 MW.