

1 Q. **Re: CA-NLH-019**

2 Table 1 gives the forecast Holyrood operations in Unit Operating Hours.

3 Please indicate the capacity of each unit.

4 Please present this information as a capacity factor, in relation to Holyrood's  
5 maximum power output.

6

7

8 A. The capacity for each of the Holyrood units is as follows:

Holyrood Unit	Net Capacity (MW)
Unit 1	161.5
Unit 2	161.5
<u>Unit 3</u>	<u>142.5</u>
Total	465.5

9 The following table presents the information in CA-NLH-019 as a capacity factor, in  
10 relation to Holyrood's maximum power output indicated above.

Holyrood Capacity Factor Forecast 2014 to 2020		
Year	Holyrood Net Production (GWh)	Holyrood Capacity Factor (%)
2014F	1,373	34%
2015F	1,593	39%
2016F	1,651	40%
2017F	1,509	37%
2018F	821	20%
2019F	20	0%
2020F	20	0%
<u>Notes:</u>		
Load Forecast (2014-2015) as per Hydro's Jun, 2014 Forecast		
Load Forecast (2016-2020) as per Hydro's Nov, 2014 Forecast		