

1 Q. **Natuashish**

2 **Re: IN-NLH-096, IN-NLH-097**

3 Please provide the following information in relation to the Natuashish electrical
4 system:

5 • Diesel generator

6 o Number of gensets, and installed capacity of each;

7 o Manufacturer and model of each;

8 o Number of running hours to date of each;

9 o Expected service life;

10 o Number of running hours before major overhaul.

11 • Distribution system

12 o Peak capacity

13

14

15 A. See table below with information requested.

16

Natuashish Unit and Distribution System Data

Location	Unit Number	Prime (kW)	Mfg	Model	Running Hours to Feb 28, 2015	Expected Service Life (hrs)	Frequency of Major Overhaul (hrs)	Distribution Peak Capacity (kW)
Natuashish	2068	671	Caterpillar	D-3412	57713	100,000	20,000	> 5000
	2069	945	Caterpillar	D-3508	62457	100,000	20,000	
	2070	945	Caterpillar	D-3508	57125	100,000	20,000	
	2076	671	Caterpillar	D-3412	54933	100,000	20,000	