

1 Q. **Re: IN-NLH-006 (Rev. 1, Nov 26-14)**

2 The revised response indicates that the load forecasts presented were prepared in
3 spring of 2013. Have these forecasts been updated since spring of 2013? If so,
4 please provided (*sic*) the updated forecasts.

5
6
7 A. The table below provides Hydro's load forecast for its isolated diesel systems for
8 the period 2015 through 2019 that was prepared in the spring of 2014. Please note
9 that load requirements provided in the table are net requirements and do not
10 include Hydro's station service requirements.

11

Forecast Peak and Energy Requirements For Hydro's Isolated Diesel Systems

	<u>2015</u>	<u>2016</u>	<u>2017</u>	<u>2018</u>	<u>2019</u>
Black Tickle					
Net Peak (kW)	259	254	250	245	241
Net Energy (MWh)	1,063	1,044	1,026	1,007	989
Cartwright					
Net Peak (kW)	997	1,005	1,015	1,024	1,034
Net Energy (MWh)	4,500	4,536	4,580	4,617	4,661
Charlottetown					
Net Peak (kW)	1,648	1,657	1,664	1,673	1,680
Net Energy (MWh)	5,487	5,518	5,539	5,570	5,591
Hopedale					
Net Peak (kW)	1,215	1,237	1,281	1,301	1,342
Net Energy (MWh)	5,334	5,420	5,599	5,681	5,849
Makkovik					
Net Peak (kW)	921	931	941	951	960
Net Energy (MWh)	4,175	4,214	4,252	4,292	4,330
Mary's Harbour					
Net Peak (kW)	1,090	1,092	1,095	1,096	1,098
Net Energy (MWh)	4,630	4,641	4,652	4,658	4,664
Nain					
Net Peak (kW)	1,929	1,973	2,014	2,054	2,095
Net Energy (MWh)	9,019	9,228	9,418	9,608	9,799

Forecast Peak and Energy Requirements For Hydro's Isolated Diesel Systems cont'd

	<u>2015</u>	<u>2016</u>	<u>2017</u>	<u>2018</u>	<u>2019</u>
Norman Bay					
Net Peak (kW)	55	55	55	55	55
Net Energy (MWh)	183	183	183	183	183
Paradise River					
Net Peak (kW)	64	65	65	66	66
Net Energy (MWh)	166	168	168	170	173
Port Hope Simpson					
Net Peak (kW)	763	779	794	810	826
Net Energy (MWh)	3,269	3,331	3,394	3,459	3,522
Postville					
Net Peak (kW)	465	470	474	478	483
Net Energy (MWh)	2,078	2,098	2,117	2,137	2,156
Rigolet					
Net Peak (kW)	692	708	720	732	744
Net Energy (MWh)	2,745	2,808	2,855	2,904	2,952
St. Lewis					
Net Peak (kW)	374	371	368	366	363
Net Energy (MWh)	1,471	1,461	1,451	1,441	1,432
William's Harbour					
Net Peak (kW)	68	68	68	68	68
Net Energy (MWh)	277	277	277	277	277
L'Anse au Loup					
Net Peak (kW)	5,768	5,828	5,875	5,919	5,960
Net Energy (MWh)	24,991	25,248	25,455	25,644	25,819
Island Isolated					
Net Peak (kW)	2,281	2,268	2,255	2,242	2,232
Net Energy (MWh)	7,748	7,700	7,654	7,609	7,571