

1 Q. For the 2013 test year, please provide a monthly profile of the Labrador
2 Interconnected System's requirement for capacity and energy. Is this pattern typical
3 of recent years and expected to continue?

4

5

6 A. Please see page 6 of 10 of Hydro's response to IC-NLH-030 for a monthly profile of
7 the Labrador Interconnected System's requirement for capacity and energy for the
8 2013 Test Year. The pattern of higher capacity and energy requirements in the
9 winter months and lower capacity and energy requirements in the summer months
10 is typical of recent years and is expected to continue. Please note that actual
11 month-to-month requirements are affected by weather, mining production and the
12 operating status of the Department of National Defense's electric boilers.