

1 Q. Does any spill occur at the CFLCo Churchill Falls plant and does this affect NL
2 Hydro's access to its 300 MW of recall power?

3

4

5 A. Yes, spill does occur at the reservoirs associated with the Churchill Falls plant,
6 however very infrequently. This does not affect Hydro's access to its 300 MW of
7 recall power.