

1 Q. If Alderon is provided with its anticipated annual power requirements for the Kami
2 Project, what additional power is available to meet the future needs of other
3 customers in Labrador West, such as IOCC Expansion and at what cost.

4

5

6 A. As indicated in Hydro's response to LWHN-NLH-068, Hydro will be able to call upon
7 525 MW of capacity from Churchill Falls and following the completion of the
8 Muskrat Falls and related transmission projects, will be able to call upon these
9 additional resources to meet the near-term needs of existing Labrador customers,
10 as well as Alderon. New industrial load requirements will be provided power in
11 accordance with the Labrador Industrial Rates Policy Framework that was
12 announced by Government in the fall of 2012.