

1 Q. [InterGroup Consultants Testimony, Section 7.3].

2 Has the 18 MW contractual limit imposed on the frequency converter resulted in
3 spillage at Corner Brook Pulp and Paper's Deer Lake hydroelectric facility?
4 Please provide details regarding the resulting reduction in energy production.

5 A. It is InterGroup's understanding that an inability to convert 50 HZ power to 60 Hz
6 (due to frequency converter limitations) generally leads to the 50 Hz generation
7 being used to power electric elements on CBPP's steam boiler.