

1 Q. **Reference: Regulated Activities**

2 Please provide the forecast conversion factor that best reflects the current 2014
3 production forecast for Holyrood on page 2.47.

4

5

6 A. As per Hydro's response to NP-NLH-011 – Schedule V Extension, the forecast
7 conversion factor that best reflects the current 2014 production forecast for
8 Holyrood is 615 kWh/bbl. This conversion factor is forecasted consistent with the
9 methodology as outlined on page 2.47 of the Regulated Activities evidence.