

1 Q. **Reference: Regulated Activities Evidence**

2 Loss of load hours in 2015 and beyond is above the 2.8 standard. Explain what  
3 steps Hydro is proposing to ensure adequate reliability through 2015? (Regulated  
4 Activities Evidence, page 2.42, Table 2.17)

5

6

7 A. Please note, Regulated Activities Evidence page 2.42, Table 2.17 in the previously  
8 filed GRA evidence is now page 2.68, Table 2.18 in the Evidence for Hydro's  
9 Amended Application. As well, there is no indication in Table 2.18 that Hydro will  
10 fall short of its capacity reliability target in 2015.

11

12 However, to ensure adequate reliability through 2015 and beyond, Hydro is  
13 constructing a new 123 MW combustion at Holyrood, scheduled to be in-service in  
14 December 2014. As well, for the winter period from 2014 to 2018, Hydro has signed  
15 interruptible contracts with two Industrial customers for an additional 75.8 MW of  
16 capacity that can be called upon, if required.

17

18 Please also see Hydro's response to CA-NLH-022.