

1 Q. Further to response to Request for Information NP-NLH-132:
2 Please compute the demand charge per month in wholesale rate to Newfoundland
3 Power that would be proposed (based upon the proposed rate design
4 methodology) if the 2014 forecast Holyrood capacity factor was used for the 2013
5 Test Year.

6

7

8 A. The Holyrood capacity factor using the 2014 forecast is 35.04%, compared with the
9 22.34% five-year average Holyrood capacity factor used in the 2013 Test Year. NP's
10 demand rate calculated using this functional classification ratio would be
11 \$8.76/kW/month, compared with the proposed \$9.12/kW/month.