

1 Q. Further to response to Request for Information NP-NLH-069:
2 Is the Station Service load that occurs during Holyrood's non-production months
3 (typically July, August, and September) included in Hydro's calculation of a fuel
4 conversion factor?

5

6

7 A. Yes, the Station Service load that occurs during Holyrood's non-production months
8 (typically July, August, and September) is included in Hydro's calculation of a fuel
9 conversion factor.