

1 Q. Further to the response to Request for Information NP-NLH-069 (Revision 1, Dec 3-  
2 14):  
3 Please describe how Hydro determines the Gross Average Unit Loading (kW) shown  
4 in Table 1.

5  
6  
7 A. The Gross Average Unit Loading (kW), shown in Table 1 of Hydro's response to  
8 NP-NLH-069 (Revision 1, Dec 3-14), is determined monthly based on the total gross  
9 energy output of the generating station divided by the total number of unit  
10 operating hours. The total gross energy output is determined via the sum of the  
11 meter readings for all three units and reported by Holyrood personnel monthly.  
12 The total number of unit operating hours is tracked and entered by Holyrood  
13 personnel in Hydro's Generating Equipment Status (GES) database and extracted  
14 monthly.