

1 Q. **2013 General Rate Application, Load Forecast**

2 Have there been any material changes to the 2013 load forecast since the date it
3 was prepared? If yes, provide details of the changes.

4

5

6 A. The load forecast for the Island and Labrador Interconnected systems for 2013 has
7 not been changed since it was finalized on April 12, 2013. The load forecasts for
8 Hydro's Isolated Diesel Systems were updated during the spring of 2013 and the
9 details of these changes are presented below.

Electricity Requirements for 2013 Isolated Diesel Systems (GWh)			
	2013 Test Year	Spring 2013 Forecast	Change from 2013 Test Year
L'Anse Au Loup	24.8	24.3	(0.4)
Other Labrador Diesel	41.9	41.8	(0.1)
Island Diesel	<u>8.0</u>	<u>7.7</u>	(0.3)
Total Isolated	74.6	73.8	(0.8)