

1 Q. 2013 Amended General Rate Application, November 10, 2014, Volume I,
2 Reconciliation to Original GRA Filing, page 1.5R, lines 8-12: Please provide the
3 rationale and experience used by Hydro to determine that purchased wind
4 generated energy should be classified as 100% energy-related because Hydro's
5 system planners no longer assume wind generation will be available to meet system
6 capacity requirements.

7
8
9 A. Please see Hydro's responses to IN-NLH-264, NP-NLH-043 (Revision 1, Nov 28-14)
10 and CA-NLH-021 (Revision 1, Dec 12-14) for the rationale and experience used by
11 Hydro to determine that purchased wind generated energy should be classified as
12 100% energy-related. Based on this information, while the wind farms supply
13 capacity at times, they cannot be depended on to be available during the system
14 peak or near peak periods due to the variable nature of wind conditions.