

1     Q.     Further to PUB-NLH-461, section 1.01(d) of the Supplementary Capacity Assistance  
2            Agreement with Corner Brook Pulp and Paper Limited states the maximum  
3            estimated capacity is 30 MW. The response to CA-NLH-296 states that an additional  
4            “net capacity assistance of approximately 22 MW” is available under this  
5            agreement. Please explain what is the amount of additional capacity that is actually  
6            available to Hydro under this agreement.

7  
8  
9     A.     Section 1.01(d) of the Supplementary Capacity Assistance Agreement with Corner  
10            Brook Pulp and Paper Limited (CBPP) states the maximum estimated capacity is 30  
11            MW. This represents the amount of additional load that is available to be curtailed  
12            in the CBPP Mill and the additional capacity that would be available from CBPP’s  
13            hydraulic generation. However, at this level of load curtailment at the Mill, process  
14            steam requirements would decrease significantly and the generation from the co-  
15            generation unit (8 MW) would effectively become unavailable. Therefore, a net  
16            capacity assistance of 22 MW (i.e., 30 MW less 8 MW) is available under the  
17            Supplementary Capacity Assistance Agreement.