

1 Q. Reference: Section 2, Regulated Activities, Section 2.5.4.3, Changes in Island
2 Interconnected System reserve and Newfoundland Power Generation Credit, page
3 2.43

4 Please provide a table similar to the above referenced table using the current
5 approved values rather than the proposed 2013 test year values.
6

7
8 A. Following is a table similar to the above referenced table using the current
9 approved values rather than the proposed 2013 test year values.

NP Generation Credit (kW) Using 2007 Test Year Approved Values	
Hydraulic Capacity	92,120
Thermal Capacity	43,500
Total	135,620
System Reserve	1.150
NP Generation Credit	117,930