

1 Q. **Reference: Section 2, Regulated Activities, Section 2.5.4.3, Changes in Island**
2 **Interconnected System reserve and Newfoundland Power Generation Credit, page**
3 **2.43**

4 Please provide the reasons for the changes in hydraulic and thermal capacity.
5
6

7 A. NP operates and maintains 32 hydro and five thermal generators. The capacity of
8 these generators and the number in-service may change between test years. Since
9 the previous GRA there has been an increase in hydro capacity of 5.0 MW and a
10 decrease in thermal capacity of 2.0 MW, for a net increase of 3.0 MW in total
11 capacity.
12

13 The capacity was reviewed in advance of the current GRA and the necessary
14 adjustments made.