

1 Q. As part of Hydro's conservation and demand plan, are there any programs designed
2 to reduce the island interconnected system peak demand? If so, please describe
3 them.

4

5

6 A. Hydro's CDM activities have targeted the reduction of fuel at Holyrood, achieved
7 through a focus on energy reduction. There are no programs specifically designed
8 to reduce the Island Interconnected system peak demand. However, the programs
9 currently offered target end uses that will have some impact on peak demand as
10 well as energy savings.