Page 1 of 1

1	Q.	Reference: RFI V-NLH-3
2		Attachment 1 of V-NHL-3 indicates that purchased energy from 'NP at Hydro
3		Request' is in excess of 20 ¢/kWh. What is the source of generation for this energy
4		and under what circumstances does Hydro request this energy?
5		
6		
7	A.	The purchased energy indicated as 'NP at Hydro Request' is generated from
8		Newfoundland Power's standby diesel and gas turbine generation located in various
9		areas of the Island portion of the Province. Hydro pays for the fuel used for
10		generation at its request. As indicated in Hydro's response to CA-NLH-072, this
11		generation may be requested in the event of a system emergency such as a
12		generation shortage or significant loss of transmission.