

1 Q. Reference: 2013 Amended GRA, Section 1: Introduction, page 1.8, lines 16-20  
 2 (online version)

3 Please complete the following table:

4 **Muskrat Falls and Holyrood Energy**

Year	Island Interconnected Energy from Muskrat Falls (gWh)	Holyrood Energy Production (gWh)
2017		
2018		
2019		
2020		
2021		
2022		

5

6

7 A. Please refer to the completed table below.

8

Year	Island Interconnected Energy from Muskrat Falls (GWh)	Holyrood Energy Production (GWh)
2017	0	1,509
2018	1,337	821
2019	2,051	19
2020	2,102	19
2021	1,980	210
2022	2,223	0

Notes:

1. In 2018, it is assumed that three Holyrood units will be operated during the winter and early spring for system reliability during the commissioning of the Lower Churchill assets.
2. In 2019 and 2020, Holyrood standby operation is assumed - one unit for five days at 100 MW and one unit for two days at full load.
3. In 2021, it is assumed that the remainder of the fuel in the tanks at Holyrood will be consumed.
4. The Island Interconnected System loads are as per Hydro's November 2014 Operating Load Forecast for 2017-2022.