

Undertaking 126

GT-CA-NLH-005. Explanations for differences between scoring of Pro Energy and PW Power Systems on the following items:

SP9-20 (Site grounding by NLH)

SP9-20 PW Power Systems had qualified in their tender that Hydro was to provide an adequate ground grid to connect the generators and equipment. ProEnergy's tender included the site wide grounding requirements. As such, PW Power Systems was assigned a score of 0 and ProEnergy was assigned a score of 1.0.