

Undertaking 136

Re: Newfoundland Power Feeder Restoration Issues

The Liberty Consulting Group

Transcript November 12, 2015 pg. 112, lines 8-25 and pg. 113, lines 1-23.

Excerpt from Liberty's Interim Report, April 24, 2014, on Supply Issues and Power Outages Review Island Interconnected System, pg. 64.

"Newfoundland Power also encountered another issue. Nine circuit breakers and reclosers would not close, because the cold weather had caused "stuck" mechanisms. Newfoundland Power determined that in some cases worn door seals allowed the heated air in the mechanism cabinets to escape. Repairs were made, sometimes after transferring loads to other feeders, when necessary."