

Undertaking 58

Undertake to provide the amount of commissioning energy consumed by the Holyrood CT.

2,766 MWh of energy was produced during the commissioning of the Holyrood CT. Please note that fuel consumed during the commissioning phase was not expensed to Hydro's operating accounts.