

Undertaking 59

Undertake to provide how long would you have to run the Holyrood CT to get to the proposed band of \$500,000 in terms of around the deferral account.

Hydro calculates it would take approximately 30-85 hours to reach the proposed cost variance threshold of \$500,000, dependent on unit loading.