

1 Q. (Regulated Activities Evidence page 2.16, lines 4 to 14)
2 Please provide a table showing for each year from 2013 through 2020 the number
3 of hours Holyrood is forecast to be producing energy (exclude voltage support
4 requirements) and the total amount of energy forecast to be produced by
5 Holyrood.

6
7

8 A. Please see the following table which shows, for each year from 2013 through 2020,
9 the number of hours Holyrood is forecast to be producing energy (exclude voltage
10 support requirements) and the total amount of energy forecast to be produced by
11 Holyrood.

12

Table 1

Forecast Holyrood Operating Requirements ⁽¹⁾ 2013 to 2020								
	2013TY ⁽²⁾	2014F	2015F	2016F	2017F	2018F	2019F	2020F
Holyrood Unit Operating Hours	12,900	15,600	16,700	16,100	16,200	168	168	168
Holyrood Net Production (GWh)	1,127	1,429	1,629	1,860	1,853	20	20	20

Notes: 1. Operating requirements for 2014-2017 are estimated using Hydro's June, 2013
Operating Load Forecast (OPLF)
2. Test Year

13 It should be noted that during the period of Holyrood standby operation, following
14 the interconnection via the Labrador Island Link (LIL), it is assumed the equivalent
15 of one Holyrood unit will be operated for one week per year - two days at full load
16 and five days at 100 MW.