

1 Q. **Reference: Exhibit 9.**

2 With respect to NP's curtailable load program, please file all details on the program
3 including the rate schedule, the compensation paid to customers, the justification
4 that NP or Hydro can use to initiate an interruption, and the number of
5 interruptions, by month (showing the number of interruptions, the capacity and
6 energy interrupted, and the number of customers affected) since the 2008.

7

8

9 A. In the event of a system emergency such as a generation shortage or significant loss
10 of transmission, Hydro follows a guideline which incorporates a series of actions in
11 order to minimize the impact to customers. Depending on the severity of the
12 situation, Hydro may call on Newfoundland Power to interrupt its curtailable load.
13 A review of Hydro's control centre diaries could find indications of only two such
14 requests since 2008, both occurring in 2013. The first occurred on January 25 at
15 16:09 hours and the second on January 28 at 14:00 hours. Both requests were
16 denied for reasons unnoted at the time.

17

18 With regard to the details of the program as it is internally administered and
19 initiated by Newfoundland Power, Hydro does not track this information.