

1 Q. **Reference: Exhibit 9 page 19.**

2 Please confirm that none of Hydro's current or planned CDM programs provide
3 capacity-related load reductions, or any energy savings at the time of system peak.

4

5

6 A. Hydro's focus is on fuel savings through CDM and as a result has developed
7 programs targeting energy savings. There are no programs currently designed to
8 reduce system peak, however, many of these programs implement technologies
9 that may have an impact on system peak. As of the end of 2012, Hydro estimates
10 these impacts as being less than 1 MW.