

1    Q.    Please provide, by year, the number of times Hydro's gas turbines and the St.  
2    Anthony and Hawke's Bay diesels were dispatched for capacity reasons, and  
3    indicate the total kW.h generation of each source (gas turbines versus diesel) by  
4    year.

5

6

7    A.    Please refer to the table below. Hydro has provided the requested information for  
8    the period 2007-2013. It should be noted that Hydro has interpreted the request to  
9    refer to operation to support the load on the Bulk Island Interconnected system. As  
10   such, operation to support area requirements (e.g., the Great Northern Peninsula or  
11   Avalon Peninsula) has been excluded.

12

**Table 1**  
**Operation of Island Interconnected Gas Turbines and Diesels for Capacity Reasons**  
**2007-2013**

	2007	2008	2009	2010	2011	2012	2013
<b>Hardwoods Gas Turbine</b>							
Number of Operations	-	4	-	-	-	-	5
Energy Produced (kWh)	-	806,355	-	-	-	-	563,355
<b>Stephenville Gas Turbine</b>							
Number of Operations	-	4	-	-	-	-	3
Energy Produced (kWh)	-	119,448	-	-	-	-	612,387
<b>St. Anthony Diesel Plant</b>							
Number of Operations	-	1	-	-	-	-	15
Energy Produced (kWh)	-	966	-	-	-	-	474,728
<b>Hawkes Bay Diesel Plant</b>							
Number of Operations	-	-	-	-	-	-	15
Energy Produced (kWh)	-	-	-	-	-	-	355,304