

1 Q. **Re: Rates Schedules pages 23-24 of 47**

2 Please provide the number of customers, the total energy consumption (GWh) and
3 the total demand (MW) for each rate class in each of the following communities:
4 each of the Isolated communities in Labrador, Sheshatshiu, Natuashish, Northwest
5 River, Happy Valley-Goose Bay, Labrador City, and Wabush.

6

7

8 A. Please see the following tables for Wabush and Labrador City, and Hydro's response
9 to IC-NLH-030 which provides Hydro's forecasts that include customer, energy
10 consumption (in MWh) and demands (in kW/kVA) by rate class. Please note that
11 Hydro does not prepare individual load forecasts by community but does so for
12 distribution system. Also, Hydro does not forecast demand for rate classes without
13 a demand charge. Natuashish is currently operated by Hydro for the Mushuau Innu
14 First Nation (MIFN). Full cost recovery and load for this system is not forecast on a
15 rate class basis.

Hydro Rural System Sales Forecast for 2013

Labrador City														Customers
Monthly System Sales in MWh														
Rate	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total	
1.10	99	89	74	54	42	31	24	25	32	49	64	86	669	129
1.12	20505	18711	15701	12078	8924	6322	4517	4700	6433	10372	13730	17657	139650	3745
2.10	208	151	151	119	106	89	81	85	91	100	128	165	1474	123
2.20	2723	2436	2370	1839	1460	1155	1081	1021	1160	1510	1942	2502	21199	208
2.30	6494	5839	5652	4201	3126	2382	2076	2206	2763	3711	4716	5996	49162	65
2.40	807	792	857	723	545	245	194	215	282	872	964	1092	7588	2
Lighting	46	46	46	46	46	46	46	46	46	46	46	46	552	101
Total	30882	28064	24851	19060	14249	10270	8019	8298	10807	16660	21590	27544	220294	4373
Demand in kW/kVa														
2.20	6822	6218	6750	5916	5686	4748	4035	4290	4835	5809	6008	6898		
2.30	14133	12558	13556	11725	10661	8472	6948	7768	9562	11389	11950	13641		
2.40	1586	1548	1648	1460	1238	1092	704	742	1105	2276	1965	2023		

Wabush															Customers
Monthly System Sales in MWh															
Rate	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total		
1.10	91	83	69	51	37	27	20	21	26	39	57	75	596	150	
1.12	5087	4698	3987	3042	2293	1640	1172	1253	1688	2684	3660	4896	36100	1008	
2.10	99	98	95	103	91	72	58	53	55	62	80	84	950	97	
2.20	1791	1791	1614	1344	923	633	480	439	556	803	1097	1439	12910	113	
2.30	3257	3146	2893	2401	1695	1201	986	910	1080	1722	2262	2747	24300	41	
2.40	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Lighting	17	17	17	17	17	17	17	17	17	17	17	17	204	33	
Total	10342	9833	8675	6958	5056	3590	2733	2693	3422	5327	7173	38436	75060	1442	
Company Use	47	54	50	42	28	20	18	17	15	22	27	35	375	6	
Demand in kW/kVa															
2.20	4015	4179	4140	3956	3594	3003	2288	2245	2772	3417	3639	4073			
2.30	7226	7121	6992	6634	6188	5309	4325	4247	4869	6335	6513	7120			