

1 Q. Re: NLH Evidence, Section 1, page 1.13, lines 8-17

2 Please present in tabular form the evolution of energy requirements for a) Labrador
3 isolated communities and b) the L'Anse au Loup system, starting prior to the Lac
4 Robertson interconnection.

5

6

7 A. The table on Page 2 presents the evolution of net energy requirements for Labrador
8 isolated communities and the L'Anse au Loup System, starting in 1995. The net
9 energy requirements for Labrador Isolated communities do not include L'Anse au
10 Loup, Davis Inlet or Natuashish.

	Net MWh <u>1995</u>	MWh Change to <u>1996</u>	MWh Change to <u>1997</u>	MWh Change to <u>1998</u>	MWh Change to <u>1999</u>	MWh Change to <u>2000</u>	MWh Change to <u>2001</u>	MWh Change to <u>2002</u>	MWh Change to <u>2003</u>	MWh Change to <u>2004</u>	MWh Change to <u>2005</u>	MWh Change to <u>2006</u>	MWh Change to <u>2007</u>	MWh Change to <u>2008</u>	MWh Change to <u>2009</u>	MWh Change to <u>2010</u>	MWh Change to <u>2011</u>	MWh Change to <u>2012</u>	MWh Change to <u>2013</u>	Forecast Net MWh <u>2013</u>
Labrador Isolated	25,656	(134)	466	1,145	920	1,662	3,605	1,476	(224)	501	(642)	(417)	1,324	1,081	1,223	(350)	1,459	(547)	3,701	41,908
L'Anse au Loup	9,502	155	509	617	781	801	1,461	872	564	1,092	(405)	93	1,515	939	1,868	550	2,379	(1,243)	2,718	24,767