

1 Q. **Re: NLH Evidence, Section 2, page 2.16, lines 10-12**

2 Please provide a graph indicating historical hydraulic inflows used for system
3 planning, and indicating the critical dry sequence.

4

5

6 A. The chart below shows the total inflows in each year from 1950 to 2012, in millions
7 of cubic metres to Hydro's main reservoirs: Victoria, Meelpaeg and Long Pond in
8 the Bay d'Espoir System, Hinds Lake and Cat Arm. The critical period, from 1959 to
9 1961 is shown.

