

1 Q. **Re: CA-NLH-019**

2 Table 1 gives the forecast Holyrood operations in Unit Operating Hours.

3 Please indicate the capacity of each unit.

4 Please present this information as a capacity factor, in relation to Holyrood's
5 maximum power output.

6

7

8 A. The capacity for each of the Holyrood units is as follows:

Holyrood Unit	Net Capacity (MW)
Unit 1	161.5
Unit 2	161.5
<u>Unit 3</u>	<u>142.5</u>
Total	465.5

9 The following table presents the information in CA-NLH-019 as a capacity factor, in
10 relation to Holyrood's maximum power output indicated above.

Holyrood Capacity Factor 2013 Test Year and 2014-2020 Forecast		
	Holyrood Net Production (GWh)	Holyrood Capacity Factor (%)
2013TY	1,127	28%
2014F	1,429	35%
2015F	1,629	40%
2016F	1,860	45%
2017F	1,853	45%
2018F	20	0%
2019F	20	0%
2020F	20	0%

Notes:
Load Forecast for 2013 as per Hydro's April, 2013 Forecast
Load Forecast for 2014-2017 as per Hydro's June, 2013 Forecast