

1 Q. Further to response to Request for Information NP-NLH-075:
2 Please provide the impact on the revenue requirement for the Island
3 Interconnected System of using the median of the hydraulic probability distribution
4 (i.e., 4,590 GWh) rather than the mean (i.e., 4,533 GWh) in establishing the 2013
5 Test Year hydraulic production forecast.

6

7

8 A. The table below provides the impact on the revenue requirement for the Island
9 Interconnected System of using the median of the hydraulic probability distribution
10 (i.e., 4,590 GWh) rather than the mean (i.e., 4,533 GWh) in establishing the 2013
11 Test Year hydraulic production forecast.

	Scenario		2013 Test Year Using Median Hydraulic Assumption	Difference
	2013 Test Year			
NLH Hydro (GWh)		4,533	4,590	57
NLH Holyrood (GWh)		1,127	1,070	(57)
Holyrood Conversion Factor (kWh/bbl)		612	609	(3)
Holyrood Fuel Consumption (bbls)		1,842,112	1,756,979	(85,133)
TY Holyrood Consumption Price (\$/bbl)	\$	108.74	\$	108.74
Total No. 6 Fuel Costs (\$000)	\$	200,314	\$	191,054
			\$	(9,261)

12 The 2013 Test Year No. 6 fuel consumption price is used in each scenario. The
13 impact of using the median of the hydraulic probability distribution would be to
14 reduce the revenue requirement by \$9,261,000.