

NP-NLH-295
2013 NLH General Rate Application

Page 1 of 2

1 Q. Further to Regulated Activities – Schedule II:
2 Provide the Transmission Losses as a percent of Total Deliveries by year for the
3 period 2006 to 2018F.

4

Year	Total Deliveries (GWh)	Holyrood Production (GWh)	Transmission Losses (GWh)	Transmission Losses as a % of Total Deliveries	Transmission Losses as a % of Holyrood Production
2006					
2007					
2008					
2009					
2010					
2011					
2012					
2013F					
2014F					
2015F					
2016F					
2017F					
2018F					

5

6

7

8 A. Please see the completed table on the following page.

NP-NLH-295
2013 NLH General Rate Application

Page 2 of 2

Year	Total Deliveries (GWh) ^{1,2}	Holyrood Production (GWh)	Transmission Losses (GWh)	Transmission Losses as a % of Total Deliveries	Transmission Losses as a % of Holyrood Production
2006	5,775.1	740.3	207.0	3.58%	27.96%
2007	6,206.9	1,255.6	182.1	2.93%	14.50%
2008	6,097.8	1,080.2	196.0	3.21%	18.14%
2009	5,917.5	939.9	195.5	3.30%	20.80%
2010	5,792.2	803.1	210.3	3.63%	26.19%
2011	6,066.0	885.3	220.6	3.64%	24.92%
2012	6,214.5	855.8	226.1	3.64%	26.42%
2013F	6,450.0	1,127.4	230.8	3.58%	20.47%
2014F	6,794.7	1,428.9	243.1	3.58%	17.01%
2015F	7,018.6	1,629.1	238.0	3.39%	14.61%
2016F	7,262.6	1,860.1	233.0	3.21%	12.53%
2017F	7,256.9	1,852.9	232.5	3.20%	12.55%
2018F ³	7,286.0	20.0	233.5	3.20%	n/a

Notes:

1. Load Forecast for 2013 as per Hydro's April 2013, forecast
2. Load Forecast for 2014-18 as per Hydro's June 2013, forecast
3. Holyrood planned to be run in Standby mode following interconnection via the Labrador Island Link (LIL).