

- 1 Q. Further to the response to IN-NLH-052, confirm that the numbers for SAIFI and
 2 SAIDI in this response include planned and unplanned outages and, if planned and
 3 unplanned outages are included, restate the information separating the planned
 4 and unplanned numbers.
 5
 6
- 7 A. Hydro confirms that the numbers for SAIFI and SAIDI in its response to IN-NLH-052
 8 include planned and unplanned outages. The tables below restate the information,
 9 separating the planned and unplanned numbers.

Table 1

SAIFI - Planned Interruptions per customer						
	2008	2009	2010	2011	2012	Average (2008-2012)
Hydro Corporate	1.16	0.95	0.81	0.77	1.13	0.96
Labrador Interconnected	1.38	1.10	1.12	0.99	1.63	1.25
Labrador Isolated	1.19	3.65	3.66	0.90	3.21	2.52
Labrador City	2.03	0.95	1.03	0.06	1.44	1.09
Wabush	2.96	4.32	1.08	0.68	3.97	2.60
Happy Valley	0.38	0.34	1.22	1.87	1.11	1.00

Table 2

SAIFI - Forced Interruptions per customer						
	2008	2009	2010	2011	2012	Average (2008-2012)
Hydro Corporate	5.16	3.58	2.71	4.92	3.24	3.92
Labrador Interconnected	5.69	6.14	2.73	7.18	3.81	5.09
Labrador Isolated	12.66	10.22	8.24	7.38	6.38	8.92
Labrador City	0.06	8.99	3.45	5.27	4.31	4.44
Wabush	9.37	10.10	1.99	8.21	5.30	6.93
Happy Valley	9.53	2.57	2.32	8.51	2.96	5.14

Table 3

SAIDI - Planned Outage hours per customer						
	2008	2009	2010	2011	2012	Average (2008-2012)
Hydro Corporate	3.23	2.90	1.44	1.47	3.35	2.48
Labrador Interconnected	3.41	5.31	2.38	1.08	5.10	3.46
Labrador Isolated	1.87	4.05	4.10	0.42	9.12	3.94
Labrador City	5.39	3.62	3.03	0.12	5.42	3.51
Wabush	7.97	27.23	3.08	1.30	8.39	9.44
Happy Valley	0.43	0.70	1.63	1.84	3.88	1.73

Table 4

SAIDI - Forced Outage hours per customer						
	2008	2009	2010	2011	2012	Average (2008-2012)
Hydro Corporate	7.95	7.76	4.99	14.84	4.90	8.09
Labrador Interconnected	1.34	19.68	3.95	10.26	4.18	7.85
Labrador Isolated	26.00	8.70	8.16	10.50	6.00	11.75
Labrador City	0.05	35.83	4.69	12.44	5.53	11.66
Wabush	5.23	33.70	3.05	16.19	9.25	13.41
Happy Valley	1.37	1.83	3.56	6.75	1.56	3.04