

1    Q.    **Reference: RFI NP-NLH-132**

2        Please provide the Holyrood capacity factor that was approved in 2007 and the  
3        actual Holyrood capacity factors for the years 2007 to 2012.

4

5

6    A.    The 2007 Test Year Holyrood capacity factor was 40.83%. The actual Holyrood  
7        capacity factors for the years 2007 to 2012 are presented in Hydro's response to  
8        NP-NLH-146.