

1 Q. Please describe the role of the Holyrood black start function during the supply
2 disruptions on the Island Interconnected System during the period January 2 - 6,
3 2014.

4

5

6 A. The Holyrood blackstart function was not required during the period of supply
7 disruptions on the Island Interconnected System over the period January 2 to 6,
8 2014. During this period, when system disturbances resulted in Holyrood plant
9 outages on January 4 and 5, 2014, the 230 kV transmission lines into the Holyrood
10 Terminal Station were able to be restored quickly, thus providing station service
11 requirements.