

1 Q. Have the supply disruptions on the Island Interconnected System during the period
2 January 2 – 6, 2014 period changed Hydro's opinion of what is needed for black
3 start at Holyrood? For example, is it desirable to abort the diesel plant black start
4 alternative and advance the 60 MW combustion turbine project?

5

6

7 A. The supply disruptions on the Island Interconnected System during the period
8 January 2 to 6, 2014 have not changed Hydro's opinion of what is needed for
9 blackstart at Holyrood.

10

11 The blackstart diesel plant is proposed to fulfill the blackstart requirement for the
12 remainder of the current operating season through June 2015. A combustion
13 turbine project (if it is the chosen option) cannot be advanced to be in-service prior
14 to June 2015.