

1 Q. (Re: Response to CA-NLH-16) Please update the response to CA-NLH-16 in light of  
2 the current schedule for the 100 MW combustion turbine project. Specifically, has  
3 Hydro changed its opinion of what is needed for black start at Holyrood following  
4 the outage events of January 2014?

5

6

7 A. The supply disruptions on the Island Interconnected System during the period  
8 January 2 to 8, 2014 have not changed Hydro's opinion of what is needed for  
9 blackstart at Holyrood. Blackstart capability was not an issue during the events of  
10 January 2014.

11

12 The blackstart diesel plant will fulfill the blackstart requirement until the new  
13 combustion turbine comes in service.