

1 Q. (PUB-NLH-23) Is it accurate to say that the purpose of the diesel plant is to reduce
2 the outage time by up to 11 hours in the unlikely event that the transmission
3 system connected to HTGS becomes unavailable?
4

5

6 A. In the event of a trip of the Holyrood station and loss of station service from the
7 power system, the blackstart diesels will be used to keep essential equipment warm
8 thereby accelerating the time it will take for the plant to start supplying customer
9 load. Eleven hours is an estimate, and is dependent on many factors relating to the
10 start-up and operation of generating unit equipment.